

N O T I C E

THIS DOCUMENT HAS BEEN REPRODUCED FROM
MICROFICHE. ALTHOUGH IT IS RECOGNIZED THAT
CERTAIN PORTIONS ARE ILLEGIBLE, IT IS BEING RELEASED
IN THE INTEREST OF MAKING AVAILABLE AS MUCH
INFORMATION AS POSSIBLE



National Aeronautics and
Space Administration

Lyndon B. Johnson Space Center
Houston, Texas 77058

JSC-16517

MARCH 1980

(NASA-TM-80795) STEADY-STATE ANALYSIS OF A
FAULTED THREE-PHASE FOUR-WIRE SYSTEM
SUPPLYING INDUCTION MOTORS WITH NEUTRALS
CONNECTED AND OTHER SINGLE-PHASE
LINE-TO-NEUTRAL LOADS (NASA) 67 p


N80-22596

Unclas
G3/33 18484

AVIONICS SYSTEMS DIVISION

INTERNAL NOTE EH-80-03

STEADY-STATE ANALYSIS OF A FAULTED THREE-PHASE
FOUR-WIRE SYSTEM SUPPLYING INDUCTION MOTORS WITH
NEUTRALS CONNECTED AND OTHER SINGLE-PHASE
LINE-TO-NEUTRAL LOADS




AVIONICS SYSTEMS DIVISION

INTERNAL NOTE EH-80-03


STEADY-STATE ANALYSIS OF A FAULTED THREE-PHASE
FOUR-WIRE SYSTEM SUPPLYING INDUCTION MOTORS WITH
NEUTRALS CONNECTED AND OTHER SINGLE-PHASE
LINE-TO-NEUTRAL LOADS

PREPARED BY



Marion E. Wood

APPROVED BY



R. E. Wilson, Chief
Power Distribution and Control Branch



John F. Hanaway, Chief
Avionics Systems Division

NATIONAL AERONAUTICS AND SPACE ADMINISTRATION
LYNDON B. JOHNSON SPACE CENTER
Houston, Texas

March 1980

CONTENTS

<u>Section</u>	<u>Page</u>
TITLE	i
SIGNATURE PAGE	ii
TABLE OF CONTENTS	iii
LIST OF FIGURES	v
LIST OF IMPORTANT SYMBOLS	vii
ABSTRACT	ix
 1.0 <u>INTRODUCTION</u>	 1
1.1 BACKGROUND OF PROBLEM	1
1.2 STATEMENT OF PROBLEM	1
1.3 REVIEW OF THE LITERATURE	5
 2.0 <u>THEORETICAL DEVELOPMENT</u>	 7
2.1 SYMMETRICAL COMPONENTS	7
2.2 EQUIVALENT CIRCUIT OF MOTORS	11
2.3 ANALYSIS OF SERIES FAULT	15
2.4 ANALYSIS OF SHUNT FAULT	22
2.5 TWO-PHASE STARTING	25
 3.0 <u>COMPUTER ANALYSIS</u>	 26
3.1 PROGRAM DESCRIPTION (SOPSFs)	26
3.2 FLOW DIAGRAM FOR "SOPSFs"	28
3.3 PROGRAM DESCRIPTION (SOTPMs)	31
3.4 COMPUTER RESULTS	32

<u>Section</u>	<u>Page</u>
4.0 CONCLUSIONS AND RECOMMENDATIONS	42
4.1 CONCLUSIONS	42
4.2 RECOMMENDATIONS	43
REFERENCES	44
APPENDIX A - FORTRAN LISTING - "SOPSFS"	A-1
APPENDIX B - FORTRAN LISTING - "SOTPMS"	B-1

LIST OF FIGURES

<u>Number</u>	<u>Title</u>	<u>Page</u>
1	SIMPLIFIED SCHEMATIC DIAGRAM OF AC SYSTEM SHOWING SIMULATED SERIES FAULT	3
2	SIMPLIFIED SCHEMATIC DIAGRAM OF AC SYSTEM SHOWING SHUNT FAULT	4
3	SCHEMATIC DIAGRAM OF 3-PHASE INDUCTION MOTOR STATOR WINDING SHOWING COUPLING AND BACK EMF . .	10
4	ZERO SEQUENCE EQUIVALENT CIRCUIT	12
5	POSITIVE SEQUENCE EQUIVALENT CIRCUIT	12
6	NEGATIVE SEQUENCE EQUIVALENT CIRCUIT	12
7	SERIES FAULT	16
8	CONNECTION DIAGRAM FOR SERIES FAULT	16
9	NETWORK REDUCTION OF POSITIVE SEQ. CIRCUIT . . .	17
10	NEG. SEQ. CKT. (REDUCED)	17
11	ZERO SEQ. CKT. (REDUCED)	17
12	SYSTEM INTERCONNECTION DIAGRAM - SERIES FAULT .	19
13	REDUCED INTERCONNECTION DIAGRAM - SERIES FAULT	19
14	SIMPLIFIED SCHEMATIC OF SHUNT FAULT	23
15	SIMPLIFIED DIAGRAM OF AC SYSTEM SHOWING TEST MOTOR STARTING ON TWO PHASES	27
16	SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 0.1 HP MOTOR LOAD	34
17	SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 0.25 HP MOTOR LOAD	35
18	SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 0.5 HP MOTOR LOAD	36
19	SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 0.75 HP MOTOR LOAD	37

<u>Number</u>	<u>Title</u>	<u>Page</u>
20	SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 1.0 HP MOTOR LOAD	38
21	GENERATED MOTOR CURRENTS DURING SERIES FAULT . .	39
22	GENERATED MOTOR CURRENTS DURING SHUNT FAULT . .	40
23	GENERATED VOLTAGE ON PHASE A DURING SERIES FAULT	41

LIST OF IMPORTANT SYMBOLS

a	- Vector Operator Equal $\cos\left(\frac{2\pi}{3}\right) + j\sin\left(\frac{2\pi}{3}\right)$
V_a, V_b, V_c	- "ABC" Applied Voltages (Phase-to-Neutral)
I_a, I_b, I_c	- "ABC" System Currents
X_c	- Mutual Reactance Between Stator Phases
R_s, R_l	- Stator Resistance of Motor
X_s	- Self Reactance of Stator
E'_a, E'_b, E'_c	- "ABC" Back EMF Voltages
\underline{A}	- Defined As
V_{abc}	- "ABC" Applied Voltages (Matrix Form)
V_{zpn}	- "ZPN" Applied Voltages (Matrix Form)
Z_p	- Primitive Impedance Matrix
E'_{abc}	- "ABC" Back EMF Voltages (Matrix Form)
Z_s	- $R_s + jX_s$
Z_c	- $0 + jX_c$
V_z, V_p, V_n	- "ZPN" Applied Voltages
E'_z, E'_p, E'_n	- "ZPN" Back EMF Voltages
Z_{zp}	- Rotor Impedance to Positive Sequence Current
Z_{zn}	- Rotor Impedance to Negative Sequence Current
P_{br}	- Blocked Rotor Input Power (Motor)
I_{br}	- Blocked Rotor Line Current (Motor)
V_{br}	- Blocked Rotor Line Voltage (Motor)
I_{nl}	- No Load Line Current (Motor)
V_{nl}	- No Load Line Voltage (Motor)
R_2	- Rotor Resistance of Motor
X_l	- Stator Reactance of Motor

LIST OF IMPORTANT SYMBOLS (CONT.)

X_2	- Rotor Reactance of Motor
X_m	- Mutual Reactance of Motor
Z_z	- Impedance to Zero Sequence Current
PU	- Per Unit Values
CHP	- Connected Horsepower
Z_1	- Impedance of Non-Motor Loads
R	- Resistance of Non-Motor Loads
VAC	- Volt-Amperes Connected
Z_{ps}	- System Impedance to Positive Sequence Currents
Z_{ns}	- System Impedance to Negative Sequence Currents
Z_{zs}	- System Impedance to Zero Sequence Currents
E_{ap}	- Positive Sequence Input Voltage to Phase "A" of the Equivalent Circuit
S	- Motor Slip
A//B	- Circuit "A" in Parallel with Circuit "B"
$E_{aa'}, E_{bb'}, E_{cc'}$	- Voltage Drops Across Series Fault
I_{zm}, I_{pm}, I_{mm}	- "ZPN" Motor Currents
I_{am}, I_{bm}, I_{cm}	- "ABC" Motor Currents
I_{a1}, I_{b1}, I_{c1}	- "ABC" Currents into Non-Motor Load
V_{am}, V_{bm}, V_{cm}	- "ABC" Voltages at Motor Terminals

ABSTRACT

Four-wire Wye connected a.c. power systems exhibit peculiar steady-state fault characteristics when the fourth wire of three-phase induction motors is connected. This type of system is used to provide additional motor redundancy on power systems of spacecraft such as the Space Shuttle Orbiter. In the event of the loss of one phase of power source due to a series or shunt fault, currents higher than anticipated will result on the remaining two phases. This is due to the magnetic coupling between phases of the motors. This report develops a theoretical approach to compute the fault currents and voltages. A FORTRAN program is also developed and is included in the appendix.

1.0 INTRODUCTION

1.1 BACKGROUND OF PROBLEM

The a.c. power systems on spacecraft differ in many respects from those of aircraft systems. Whereas aircraft generally use engine-driven alternators as the prime power source, spacecraft generally use d.c. sources such as fuel cells or solar cells. The a.c. power is then derived from some form of static inversion device. As an example, the Shuttle Orbiter spacecraft utilizes three single-phase static inverters phased together to provide a 115-volt, 400 Hz, 4-wire Wye power system. This 4-wire system has the advantage that it provides a capability to operate polyphase induction motors after the loss of any one phase. Certain precautions must be observed, however, in the application of a system of this type, and an understanding of its fault characteristics is essential. The Orbiter system will be used as an example throughout the remainder of this thesis.

1.2 STATEMENT OF PROBLEM

The purpose of this investigation is to develop a model, using both analytical and empirical methods, to determine performance characteristics of the system during series and shunt faults. It is not intended as an exact or generalized model since several simplifying assumptions are made. The model is expected to be sufficiently accurate to permit a system designer or operations engineer to perform load and redundancy management studies.

Figure 1 shows a simplified schematic of one string of an a.c. system. This diagram depicts a series fault simulated with an open switch. One example of the series fault is the loss of one of the three single-phase inverters. A shunt fault is shown in figure 2. A phase-to-neutral short circuit is shown on phase A of sub-bus 3. The single-phase circuit breaker protecting this phase has opened. For the purpose of this analysis, the circuit breaker is assumed to trip properly and clear the fault from the source. This type of fault is of concern only on those sub-buses using single-phase breakers as opposed to three-phase breakers, since a three-phase breaker would clear all three phases.

Both of these faults are of concern for a system of this type because of the magnetic coupling between phases of the three-phase induction motors. In case of a series fault, the motors will continue to run on two phases and, through generator action, will supply power to the non-motor loads connected to the various sub-buses. This will add additional load to the two remaining phases and possibly overload the inverters or trip the circuit breakers. As stated previously, the shunt fault is of no concern on those sub-buses using three-phase circuit breakers. For sub-buses using single-phase breakers, the situation is similar to the series fault. Due to the magnetic coupling between phases, the two remaining phases will continue to supply current to the phase-to-neutral fault. Depending on the number and size of motors connected,




FIGURE 1. SIMPLIFIED SCHEMATIC DIAGRAM OF AC SYSTEM SHOWING SIMULATED SERIES FAULT




FIGURE 2. SIMPLIFIED SCHEMATIC DIAGRAM OF AC SYSTEM SHOWING SHUNT FAULT

the two remaining phases could be overloaded and trip circuit breakers. A secondary concern of the series fault is the magnitude and phase of the voltage on the faulted bus. This is a concern if the equipment connected to this bus could be damaged by low voltage. The model to be developed will enable one to compute these voltage and current parameters for various loading conditions. It will also permit isolation of one motor of varying horsepower and computation of its starting current with and without other motors running.

1.3 REVIEW OF THE LITERATURE

Methods for the analysis of unbalanced polyphase systems have been known for many years. In 1918, C. L. Fortescue¹ showed that any three phasors, Q_a , Q_b , and Q_c , which are unsymmetrical in phase and/or magnitude, can be resolved into two sets of balanced (symmetrical) three-phase phasors and one set of three equal phasors. The set of three equal phasors, Q_{ao} , Q_{bo} , and Q_{co} , is commonly referred to as the "Zero Phase Sequence" set. The two balanced three-phase phasors are commonly referred to as the "Positive Phase Sequence" set and the "Negative Phase Sequence" set. The positive phase sequence set rotates in the counter-clockwise sense and the negative phase sequence set rotates in the reverse (clockwise) sense. For the remainder of this report, phase quantities will be referred to as "ABC" quantities or as the "ABC" domain. Sequence quantities will be referred to as "ZPN" quantities or as the "ZPN" domain. Fortescue defined an operator "a" where:

$$a \triangleq \cos \left(\frac{2\pi}{3} \right) + j \sin \left(\frac{2\pi}{3} \right) \text{ and } a^2 \triangleq \cos \left(\frac{4\pi}{3} \right) + j \sin \left(\frac{4\pi}{3} \right)$$

Two useful properties of the phasor operator "a" are:

$$1 + a + a^2 = 0$$

$$a \cdot a^2 = 1$$

He then developed a transformation matrix [C] where:

$$[C] = \left(\frac{1}{3}\right) \cdot \begin{bmatrix} 1 & 1 & 1 \\ 1 & a & a^2 \\ 1 & a^2 & a \end{bmatrix}$$

which when applied to the "ABC" quantities, transforms them into "ZPN" quantities as follows:

$$\begin{bmatrix} Q_z \\ Q_p \\ Q_n \end{bmatrix} = [C] \cdot \begin{bmatrix} Q_a \\ Q_b \\ Q_c \end{bmatrix}$$

Similarly, the inverse of the [C] matrix,

$$[C^{-1}] = \begin{bmatrix} 1 & 1 & 1 \\ 1 & a^2 & a \\ 1 & a & a^2 \end{bmatrix}$$

could be applied to "ZPN" quantities to transform back into the "ABC" quantities:

$$\begin{bmatrix} Q_a \\ Q_b \\ Q_c \end{bmatrix} = [C^{-1}] \cdot \begin{bmatrix} Q_z \\ Q_p \\ Q_n \end{bmatrix}$$

The factor $\left(\frac{1}{3}\right)$ in the [C] matrix permits working with single-phase quantities in the "ZPN" domain; however, recent authors such as P. L. Alger² have suggested that the transformation should maintain power invariance in both domains and they suggest using a factor $(1/\sqrt{3})$ in both the [C] matrix and its inverse $[C^{-1}]$. Either approach is acceptable if properly

used; however, the earlier version as suggested by Fortescue is used in this report. Numerous other techniques have been proposed and used successfully for the analysis of unbalanced systems. The symmetrical component method, however, is the most widely used technique.

2.0 THEORETICAL DEVELOPMENT

2.1 SYMMETRICAL COMPONENTS

The first step will be to show that the positive, negative, and zero sequence components are uncoupled and therefore can be represented by three single-phase equivalent circuits. This is frequently done in the literature for the positive and negative sequence. The zero-sequence is generally omitted because of the fact that induction motors are usually operated "3-wire" and zero-sequence currents cannot flow.

Figure 3 is a schematic diagram of an induction motor showing back EMF terms and coupling between stator phases. Kirchoff's voltage equations will now be applied to this circuit:

$$\left. \begin{aligned} V_a &= (R_s + jX_s)I_a - (jX_c)I_b - (jX_c)I_c + E'_a \\ V_b &= -(jX_c)I_a + (R_s + jX_s)I_b - (jX_c)I_c + E'_b \\ V_c &= -(jX_c)I_a - (jX_c)I_b + (R_s + jX_s)I_c + E'_c \end{aligned} \right\} \text{EQ. 1}$$

or in matrix form:

$$\begin{bmatrix} V_a \\ V_b \\ V_c \end{bmatrix} = \begin{bmatrix} (R_s + jX_s) & -jX_c & -jX_c \\ -jX_c & (R_s + jX_s) & -jX_c \\ -jX_c & -jX_c & (R_s + jX_s) \end{bmatrix} \cdot \begin{bmatrix} I_a \\ I_b \\ I_c \end{bmatrix} + \begin{bmatrix} E'_a \\ E'_b \\ E'_c \end{bmatrix} \quad \left. \right\} \text{EQ. 2}$$

where:

$|E'_a| = |E'_b| = |E'_c| \triangleq$ Magnitude of back EMF's

$jX_c \triangleq$ Mutual reactance between stator phases

$Z_s = (R_s + jX_s)$; $Z_c = (0 + jX_c)$

The primitive impedance matrix can be written as follows:

$$[Z_p] = \begin{bmatrix} Z_s & -Z_c & -Z_c \\ -Z_c & Z_s & -Z_c \\ -Z_c & -Z_c & Z_s \end{bmatrix} \quad \text{EQ. 3}$$

The symmetrical component transformation is now applied to equation 2. The transformation matrix $[C]$ was defined in section 1 and is shown below for convenience to the reader:

$$[C] = \left(\frac{1}{3}\right) \cdot \begin{bmatrix} 1 & 1 & 1 \\ 1 & a & a^2 \\ 1 & a^2 & a \end{bmatrix} \quad [C^{-1}] = \begin{bmatrix} 1 & 1 & 1 \\ 1 & a^2 & a \\ 1 & a & a^2 \end{bmatrix}$$

Equation 2 in simplified form is written as follows:

$$[V_{abc}] = [Z_p] \cdot [I_{abc}] + [E'_{abc}] \quad \text{EQ. 4}$$

The transformation of a set of voltages or currents from the "ZPN" domain to the "ABC" domain has been shown to be as follows:

$$[V_{abc}] = [C^{-1}] \cdot [V_{zpn}]$$

Substituting for the "ABC" terms in equation 4 gives the following system of equations in the "ZPN" domain:

$$[C^{-1}] \cdot [V_{zpn}] = [Z_p] \cdot [C^{-1}] \cdot [I_{zpn}] + [C^{-1}] \cdot [E'_{zpn}] \quad \text{EQ. 5}$$

Multiplying both sides of this equation by $[C]$ gives:

$$[V_{zpn}] = [C] \cdot [Z_p] \cdot [C^{-1}] \cdot [I_{zpn}] + [E'_{zpn}] \quad \text{EQ. 6}$$

Now the expression $[C] \cdot [Z_p] \cdot [C^{-1}]$ can be evaluated:

$$\left(\frac{1}{3}\right) \cdot \begin{bmatrix} 1 & 1 & 1 \\ 1 & a & a^2 \\ 1 & a^2 & a \end{bmatrix} \cdot \begin{bmatrix} Z_s & -Z_c & -Z_c \\ -Z_c & Z_s & -Z_c \\ -Z_c & -Z_c & Z_s \end{bmatrix} \cdot \begin{bmatrix} 1 & 1 & 1 \\ 1 & a^2 & a \\ 1 & a & a^2 \end{bmatrix} =$$

$$\begin{bmatrix} 1 & 1 & 1 \\ 1 & a & a^2 \\ 1 & a^2 & a \end{bmatrix} \cdot \begin{bmatrix} (Z_s - 2Z_c) & (a^2 + a) \cdot (Z_s - Z_c) & (a^2 + a) \cdot (Z_s - Z_c) \\ (Z_s - 2Z_c) & a^2 Z_s - (1 + a)Z_c & aZ_s - (1 + a^2)Z_c \\ (Z_s - 2Z_c) & aZ_s - (1 + a^2)Z_c & a^2 Z_s - (1 + a)Z_c \end{bmatrix} =$$

$$\begin{bmatrix} Z_s - 2Z_c & 0 & 0 \\ 0 & (Z_s + Z_c) & 0 \\ 0 & 0 & (Z_s + Z_c) \end{bmatrix}$$

Equation 6 can now be written as follows:

$$\begin{bmatrix} V_z \\ V_p \\ V_n \end{bmatrix} = \begin{bmatrix} Z_z & 0 & 0 \\ 0 & Z_1 & 0 \\ 0 & 0 & Z_1 \end{bmatrix} \cdot \begin{bmatrix} I_z \\ I_p \\ I_n \end{bmatrix} + \begin{bmatrix} E'_z \\ E'_p \\ E'_n \end{bmatrix} \quad \text{EQ. 7}$$

where: Z_z = zero sequence impedance

Z_1 = stator impedance for positive and negative equivalent circuits. (See figures 5 and 6.)

Since the impedance matrix in equation 7 is diagonal, it can be concluded that the sequence circuits are uncoupled and can therefore be represented as three separate single-phase circuits. Textbooks on classical induction motor theory^{2,5} show that the back EMF terms E'_p and E'_n can be represented as fictional rotor impedances multiplied by the positive and negative sequence rotor currents:




FIGURE 3 - SCHEMATIC DIAGRAM OF 3-PHASE INDUCTION MOTOR STATOR WINDING SHOWING COUPLING AND BACK EMF.

$$E'_p = (Z_{2p}) \cdot (I_{2p})$$

$$E'_n = (Z_{2n}) \cdot (I_{2n})$$

where:

Z_{2p} Δ Rotor impedance to positive sequence current

Z_{2n} Δ Rotor impedance to negative sequence current

Furthermore, since zero sequence currents are all in phase, they do not contribute to the rotating air gap flux and therefore $E'_z = 0$. Also, since the power source generates only balanced positive sequence voltages, V_z and V_n are zero. After substitution, matrix equation 7 can be written in the following form:

$$0 = (Z_z) \cdot (I_z) + 0$$


$$V_p = (Z_1) \cdot (I_p) + (Z_{2p}) \cdot (I_{2p}) \quad \text{EQ. 8}$$

$$0 = (Z_1) \cdot (I_n) + (Z_{2n}) \cdot (I_{2n})$$

From inspection of equation 8, the zero sequence equivalent circuit can be drawn. This is shown in figure 4. Equivalent circuits for the positive and negative sequences are available throughout the literature and simplified versions shown in figures 5 and 6 are generally accepted as adequate.^{2,5}

2.2 EQUIVALENT CIRCUIT OF MOTORS

For convenience of input to the computer, the non-motor loads will be expressed as volt-amperes and the computer will compute the equivalent resistance value. The motor loads will be expressed as total connected horsepower. The computer will



Note: This circuit is not required for 3-wire motors since Zero sequence currents cannot flow.

FIGURE 4 - ZERO SEQUENCE EQUIVALENT CIRCUIT




FIGURE 5 - POSITIVE SEQUENCE EQUIVALENT CIRCUIT




FIGURE 6 - NEGATIVE SEQUENCE EQUIVALENT CIRCUIT

then compute the equivalent circuit parameters for this motor load. This is an approximation, and assumes that the equivalent circuit parameters are inversely proportional to motor horsepower. This is assumed to be adequate for purposes of this analysis and is supported by Clarke³ for motors up to 5 horsepower.

The circuit parameters for the equivalent circuits shown in figures 5 and 6 can be computed from blocked rotor and no-load test data plus d.c. resistance measurements:

R_1 = Measured d.c. resistance in ohms

$$R_2 = \left(\frac{P_{br}}{3 \cdot (I_{br})^2} - R_1 \right) \text{ ohms}$$

$$X_1 + X_2 = \sqrt{\left(\frac{V_{br}}{\sqrt{3} I_{br}} \right)^2 - \left(\frac{P_{br}}{3 I_{br}^2} \right)^2}$$

$X_1 = X_2$ for class "A" motors³

$$X_m = \left(\frac{V_{nl}}{\sqrt{3} I_{nl}} - X_1 \right) \text{ ohms}$$

where: P_{br} , I_{br} , and V_{br} are, respectively, the total power input, line current, and line voltage measured with the rotor blocked.

I_{nl} and V_{nl} are the line current and the line voltage at no load.

Zero sequence parameters can be measured by connecting the three-phase windings in parallel and applying single-phase voltage from line-to-neutral, in which case we have

$$Z_z = \frac{3 \cdot (V / \phi^\circ)}{I / \theta^\circ}$$

An alternate method is to connect the three-phase windings in series and apply a single-phase voltage, in which case we have

$$Z_z = \frac{V / \phi^\circ}{3 \cdot (I / \theta^\circ)}$$

An empirical method is used to obtain the equivalent circuit parameters used for this study. Several 400 Hz aircraft-type motors were tested to obtain a typical set of equivalent circuit parameters. These included a Sawyer motor (.125 hp), three IMC motors (.125 hp, .25 hp, and .5 hp), and a Westinghouse motor (.67 hp). These motors are assumed to be typical of other motors in this general size and class category. The parameters for these motors were measured in the laboratory and average values are listed below: (Note: The following values are normalized to a common base of 0.75 hp.)

$$R_1 = 1.86 \text{ ohms}; R_2 = 3.34 \text{ ohms}; X_1 = X_2 = 4.9 \text{ ohms}$$

$$X_m = 50 \text{ ohms}; R_z = 3.2 \text{ ohms}; X_z = 3.22 \text{ ohms}$$

These parameters will now be expressed in per unit (PU) values (i.e., normalized with respect to some base value). A single string of the Orbiter a.c. system will be used as the base value.⁶

$$\text{Base volt-amperes} = 750 \text{ VA (single-phase inverter rating)}$$

$$\text{Base volts} = 120 \text{ volts (phase-to-neutral)}$$

$$\text{Base amps} = 750/120 = 6.25 \text{ amps}$$

$$\text{Base impedance} = 120/6.25 = 19.2 \text{ ohms}$$

Per unit values for this motor are as follows:

$$R_1 = 1.86/19.2 = .097 \text{ PU}; R_2 = 3.34/19.2 = .174 \text{ PU}$$

$$X_1 = X_2 = 4.9/19.2 = .256 \text{ PU}; X_m = 50/19.2 = 2.605 \text{ PU};$$

$$R_z = 3.2/19.2 = .165 \text{ PU}; X_z = 3.22/19.2 = .168 \text{ PU}$$

The computer will calculate these parameters for every set of input values of connected horsepower (CHP). As an example:

$$\text{Primary resistance for any size motor} = R_1(.75/\text{CHP})$$

Where: R_1 Δ Stator resistance in PU

.75 = Horsepower of test motor

CHP Δ Connected horsepower

2.3 ANALYSIS OF SERIES FAULT

The series fault previously shown in figure 1 can be analyzed using methods outlined in the Westinghouse Transmission and Distribution Reference Book.⁴ For purposes of this study, the series fault condition shown in figure 7 is adequate since line impedance is less than 3% and can be neglected. Westinghouse shows that the positive, negative, and zero sequence equivalent circuits can be interconnected as shown in figure 8 to analyze the series fault in the "ZPN" domain.

It will be more convenient to analyze this interconnected network if the motor equivalent circuits are reduced to their simplest form. Figure 9 shows how the positive sequence circuit can be reduced. Figures 10 and 11 show the negative and zero sequence circuits in reduced form.




FIGURE 7 - SERIES FAULT




FIGURE 8 - CONNECTION DIAGRAM FOR SERIES FAULT

Note: From Westinghouse Transmission and Distribution Handbook, Ref. 4.




FIGURE 9 - NETWORK REDUCTION OF POSITIVE SEQ. CIRCUIT




FIGURE 10 - NEG. SEQ. CKT (REDUCED)




FIGURE 11 - ZERO SEQ. CKT (REDUCED)

Positive Sequence Circuit Reduction Equation:

$$Z_{2p} \triangleq (0 + jX_m) // \left(\frac{R_2}{S} + jX_2 \right)$$
$$Z_p = Z_1 + Z_{2p} \quad \text{EQ. 9}$$

Negative Sequence Circuit Reduction Equation:

$$Z_{2n} \triangleq (0 + jX_m) // \left(\frac{R_2}{(2-S)} + jX_2 \right)$$
$$Z_n = Z_1 + Z_{2n} \quad \text{EQ. 10}$$

Zero Sequence Circuit Reduction Equation:

$$Z_z = R_z + jX_z \quad \text{EQ. 11}$$

Since the non-motor loads are resistive with no coupling between phases, the positive, negative, and zero sequence equivalent circuits are identical and the impedance of the single-phase equivalent circuit is:

$$Z_1 = R + j0 \quad \text{EQ. 12}$$

where: $R = (\text{Base Volts})^2 / \text{VAC} / \text{Base Impedance}$

VAC \triangleq Volts-Amperes-Connected

Figure 12 shows the simplified "ZPN" equivalent circuits for the motor and non-motor loads interconnected for the series fault. This circuit can be reduced further as shown in figure 13, where impedances are defined as the following parallel combinations.

$$Z_{ps} \triangleq Z_1 // Z_p$$
$$Z_{ns} \triangleq Z_1 // Z_n$$
$$Z_{zs} \triangleq Z_1 // Z_z$$




FIGURE 12 - SYSTEM INTERCONNECTION DIAGRAM - SERIES FAULT




FIGURE 13 - REDUCED INTERCONNECTION DIAGRAM - SERIES FAULT

This is the circuit which will be analyzed to obtain fault currents in the "ZPN" domain for the series fault:

$$I_p = \frac{E_{ap} \cdot (Z_{ns} + Z_{zs})}{(Z_{ps} \cdot Z_{ns}) + (Z_{ps} \cdot Z_{zs}) + (Z_{ns} \cdot Z_{zs})} \quad \text{EQ. 13}$$

$$I_n = \frac{- (E_{ap} \cdot Z_{zs})}{(Z_{ps} \cdot Z_{ns}) + (Z_{ps} \cdot Z_{zs}) + (Z_{ns} \cdot Z_{zs})} \quad \text{EQ. 14}$$

$$I_z = \frac{- (E_{ap} \cdot Z_{ns})}{(Z_{ps} \cdot Z_{ns}) + (Z_{ps} \cdot Z_{zs}) + (Z_{ns} \cdot Z_{zs})} \quad \text{EQ. 15}$$

ZPN voltages across the fault are as follows:

$$V_p = V_{xp} - V_{yp} = E_{ap} - I_p \cdot Z_{ps} \quad \text{EQ. 16}$$

$$V_n = V_{xn} - V_{yn} = -I_n \cdot Z_{ns} \quad \text{EQ. 17}$$

$$V_z = V_{xz} - V_{yz} = -I_z \cdot Z_{zs} \quad \text{EQ. 18}$$

E_{ap} is defined as the positive sequence input voltage to phase "A" of the equivalent circuit. This voltage is obtained by applying the [C] transform to the balanced input voltages:

$$\begin{bmatrix} E_z \\ E_p \\ E_n \end{bmatrix} = \left(\frac{1}{3} \right) \cdot \begin{bmatrix} 1 & 1 & 1 \\ 1 & a & a^2 \\ 1 & a^2 & a \end{bmatrix} \cdot \begin{bmatrix} E_a \\ E_b \\ E_c \end{bmatrix} \quad \text{EQ. 19}$$

where: $E_a = 1/\underline{0^\circ}$ PU; $E_b = 1/\underline{240^\circ}$ PU; $E_c = 1/\underline{120^\circ}$ PU

Therefore:

$$\begin{aligned} \begin{bmatrix} E_z \\ E_p \\ E_n \end{bmatrix} &= \left(\frac{1}{3} \right) \cdot \begin{bmatrix} 1 & 1 & 1 \\ 1 & a & a^2 \\ 1 & a^2 & a \end{bmatrix} \cdot \begin{bmatrix} 1/\underline{0^\circ} \\ 1/\underline{240^\circ} \\ 1/\underline{120^\circ} \end{bmatrix} \\ &= \left(\frac{1}{3} \right) \cdot \begin{bmatrix} 1/\underline{0^\circ} + 1/\underline{240^\circ} + 1/\underline{120^\circ} \\ 1/\underline{0^\circ} + 1/\underline{360^\circ} + 1/\underline{360^\circ} \\ 1/\underline{0^\circ} + 1/\underline{120^\circ} + 1/\underline{240^\circ} \end{bmatrix} = \begin{bmatrix} 0 \\ 1/\underline{0^\circ} \\ 0 \end{bmatrix} \end{aligned}$$

It can be seen that the single phase value for $E_p = 1/\underline{0}^\circ$ PU. This is the value to be assigned to E_{ap} . As could be expected, E_z and E_n equal zero since the input voltages are balanced.

The ZPN voltages and currents will now be transformed back into the "ABC" reference frame. Using the inverse transformation $[C^{-1}]$:

$$\begin{bmatrix} E_{aa'} \\ E_{bb'} \\ E_{cc'} \end{bmatrix} = \begin{bmatrix} 1 & 1 & 1 \\ 1 & a^2 & a \\ 1 & a & a^2 \end{bmatrix} \cdot \begin{bmatrix} V_z \\ V_p \\ V_n \end{bmatrix} \left. \vphantom{\begin{bmatrix} E_{aa'} \\ E_{bb'} \\ E_{cc'} \end{bmatrix}} \right\} \begin{array}{l} \text{Voltage drops} \\ \text{across series} \\ \text{fault.} \end{array} \quad \text{EQ. 20}$$

$$\begin{bmatrix} I_a \\ I_b \\ I_c \end{bmatrix} = \begin{bmatrix} 1 & 1 & 1 \\ 1 & a^2 & a \\ 1 & a & a^2 \end{bmatrix} \cdot \begin{bmatrix} I_z \\ I_p \\ I_n \end{bmatrix} \left. \vphantom{\begin{bmatrix} I_a \\ I_b \\ I_c \end{bmatrix}} \right\} \begin{array}{l} \text{System currents} \\ \text{from source.} \end{array} \quad \text{EQ. 21}$$

$$I_{zm} = \frac{(I_z \cdot Z_1)}{(Z_z + Z_1)} \quad \text{EQ. 22}$$

$$I_{pm} = \frac{(I_p \cdot Z_1)}{(Z_p + Z_1)} \quad \text{EQ. 23}$$

$$I_{nm} = \frac{(I_n \cdot Z_1)}{(Z_n + Z_1)} \quad \text{EQ. 24}$$

$$\begin{bmatrix} I_{am} \\ I_{bm} \\ I_{cm} \end{bmatrix} = \begin{bmatrix} 1 & 1 & 1 \\ 1 & a^2 & a \\ 1 & a & a^2 \end{bmatrix} \cdot \begin{bmatrix} I_{zm} \\ I_{pm} \\ I_{nm} \end{bmatrix} \left. \vphantom{\begin{bmatrix} I_{am} \\ I_{bm} \\ I_{cm} \end{bmatrix}} \right\} \begin{array}{l} \text{"ABC"} \\ \text{motor} \\ \text{currents} \end{array} \quad \text{EQ. 25}$$

$$\begin{bmatrix} I_{a1} \\ I_{b1} \\ I_{c1} \end{bmatrix} = \begin{bmatrix} I_a \\ I_b \\ I_c \end{bmatrix} - \begin{bmatrix} I_{am} \\ I_{bm} \\ I_{cm} \end{bmatrix} \left. \vphantom{\begin{bmatrix} I_{a1} \\ I_{b1} \\ I_{c1} \end{bmatrix}} \right\} \begin{array}{l} \text{"ABC"} \\ \text{resistive load} \\ \text{currents.} \end{array} \quad \text{EQ. 26}$$

$$\begin{bmatrix} V_{am} \\ V_{bm} \\ V_{cm} \end{bmatrix} = \begin{bmatrix} V_a \\ V_b \\ V_c \end{bmatrix} - \begin{bmatrix} E_{aa'} \\ E_{bb'} \\ E_{cc'} \end{bmatrix} \quad \left. \vphantom{\begin{bmatrix} V_{am} \\ V_{bm} \\ V_{cm} \end{bmatrix}} \right\} \begin{array}{l} \text{"ABC" voltages} \\ \text{at motor and} \\ \text{load terminals.} \end{array} \quad \text{EQ. 27}$$

This completes the analysis of the series fault. A FORTRAN program is shown later to solve the above equations on the computer.

2.4 ANALYSIS OF SHUNT FAULT

The method of solution for the shunt fault (figure 2) will be different from the one for the series fault since the terminal voltage on the faulted phase will be zero. The shunt fault is actually a simultaneous series/shunt fault since the circuit breaker on the faulted phase is assumed to have been tripped. The period of interest for this fault is after the single-phase circuit breaker has tripped. The fault is assumed to be a zero impedance short circuit to neutral; therefore, no current induced in the phase "A" motor winding will flow in the resistive load. This simplifies the problem by permitting separate computation of motor and load currents and then superimposing these to obtain system currents. Figure 14 is a simplified diagram showing terminal voltage and current flow for the shunt fault. It has been shown that the motor can be represented by three independent equivalent circuits in the "ZPN" domain. These are shown in figures 9, 10, and 11. If the applied voltages to each of these equivalent circuits are known, the "ZPN" and the "ABC" currents can be computed. The "ZPN" voltages are computed as follows:




FIGURE 14 - SIMPLIFIED SCHEMATIC OF SHUNT FAULT

$$\begin{bmatrix} V_z \\ V_p \\ V_n \end{bmatrix} = \left(\frac{1}{3}\right) \cdot \begin{bmatrix} 1 & 1 & 1 \\ 1 & a & a^2 \\ 1 & a^2 & a \end{bmatrix} \cdot \begin{bmatrix} V_a \\ V_b \\ V_c \end{bmatrix} \quad \text{EQ. 28}$$

Sample Calculation:

$$\begin{aligned} \begin{bmatrix} V_z \\ V_p \\ V_n \end{bmatrix} &= \left(\frac{1}{3}\right) \cdot \begin{bmatrix} 1 & 1 & 1 \\ 1 & a & a \\ 1 & a & a \end{bmatrix} \cdot \begin{bmatrix} 0 \\ 1/\underline{-120^\circ} \\ 1/\underline{120^\circ} \end{bmatrix} \\ &= \left(\frac{1}{3}\right) \cdot \begin{bmatrix} 1/\underline{-120^\circ} & + & 1/\underline{120^\circ} \\ 1/\underline{0^\circ} & + & 1/\underline{0^\circ} \\ 2/\underline{-120^\circ} & + & 1/\underline{120^\circ} \end{bmatrix} = \left(\frac{1}{3}\right) \cdot \begin{bmatrix} 1/\underline{180^\circ} \\ 2/\underline{0^\circ} \\ 2/\underline{180^\circ} \end{bmatrix} \end{aligned}$$

Therefore:

$$V_z = \left(\frac{-1}{3}\right) + j0$$

$$V_p = \left(\frac{2}{3}\right) + j0$$

$$V_n = \left(\frac{-2}{3}\right) + j0$$

The "ZPN" currents are computed as follows:

$$I_z = \frac{V_z}{Z_z} \quad \text{EQ. 29}$$

$$I_p = \frac{V_p}{Z_p} \quad \text{EQ. 30}$$

$$I_n = \frac{V_n}{Z_n} \quad \text{EQ. 31}$$

NOTE: Z_p , Z_n , and Z_z are computed using equations 9 through 11.

ABC motor currents are computed as follows:

$$\begin{bmatrix} I_{am} \\ I_{bm} \\ I_{cm} \end{bmatrix} = \begin{bmatrix} 1 & 1 & 1 \\ 1 & a^2 & a \\ 1 & a & a^2 \end{bmatrix} \cdot \begin{bmatrix} I_z \\ I_p \\ I_n \end{bmatrix} \quad \text{EQ. 32}$$

Since the resistive loads are not sensitive to voltage unbalance, load currents can be computed in the ABC domain.

$$I_{a1} = \frac{V_a}{Z_1} = 0 \quad \text{EQ. 33}$$

$$I_{b1} = \frac{V_b}{Z_1} \quad \text{EQ. 34}$$

$$I_{c1} = \frac{V_c}{Z_1} \quad \text{EQ. 35}$$

The system currents are as follows:

$$I_a = 0 \quad \text{EQ. 36}$$

$$I_b = I_{bm} + I_{b1} \quad \text{EQ. 37}$$

$$I_c = I_{cm} + I_{c1} \quad \text{EQ. 38}$$

This completes the computations for the shunt fault condition.

2.5 TWO-PHASE STARTING

The series fault analysis assumed all the motors on the system were lumped together and running at the same slip. This did not permit the separate computation of starting current for one motor when other motor and non-motor loads were operating. A minor change in the circuit equations for the series fault was accomplished to permit separate computation. An analysis of this sort is of particular interest since the operating motors supply current, through generator action, to the dead phase of the motor being started. Since this current is in

the proper time phase relative to the other two phases, it assists in the starting of the motor. In generating this current, however, the other motors demand more current from the bus. The computer program to be described later computes bus currents and voltages, currents to the motor being started, currents to the other operating motors, and currents being generated on the dead phase by the other operating motors. Figure 15 shows the current generated in the dead phase of the operating motors and being supplied to the test motor being started and to the non-motor loads. As the size of the non-motor increases, its current demand increases leaving less current available to start the test motor.

3.0 COMPUTER ANALYSIS

3.1 PROGRAM DESCRIPTION (SOPSFS)

A FORTRAN program is developed to calculate system currents, motor currents, non-motor currents, and bus voltages. The program is set up to permit computation of up to 10 values of slip, 10 values of connected horsepower, and 10 values of non-motor loads. It is only necessary for the user to put in values for slip, connected horsepower, and connected volt-amperes of non-motor loads. It is written in FORTRAN IV language. The computations, which basically involve the solution of equations 1-38, take place within three nested do-loops. A listing of the FORTRAN program is included in the appendix. The program is designated SOPSFS (Shuttle Orbiter power system, fault simulation).







FIG 15- SIMPLIFIED DIAGRAM OF AC SYSTEM SHOWING
 TEST MOTOR STARTING ON TWO PHASES.

ORIGINAL PAGE IS
 OF POOR QUALITY

3.2 FLOW DIAGRAM FOR "SOPSFs"







3.3 PROGRAM DESCRIPTION (SOTPMS)

The SOTPMS (Shuttle Orbiter two-phase motor starting) program is an extension of SOPSFS and permits separation of one motor (test motor) from the group of lumped motors. This permits the test motor to be operated at values of slip different from the other motors. As a result, calculations can be made with the test motor at zero speed while the other motors are operating at full speed. Operation of this program requires the user to put in values for horsepower and slip for the test motor, horsepower and slip for the other lumped motors, and volt-amperes of the non-motor loads. As presently configured, the outputs are bus currents, test motor currents, lumped motor currents, non-motor load currents, and bus voltages. These currents and voltages are complex and are printed out in rectangular coordinate form. The following example illustrates the use of the program.

Assume the loss of phase "A" inverter on AC-2. Calculate the starting and running current of a 0.5 horsepower motor when no other loads are connected to the system and when other motor and non-motor loads are connected. This example simulates the starting current of a cabin fan under various conditions of system load. It shows how the generated current from other operating motors on the bus can provide starting current to phase "A" of the cabin fan and thereby improve its starting performance.

STARTING & RUNNING CURRENTS FOR SERIES FAULT

<u>NON-MOTOR LOAD (VA)</u>	<u>MOTOR LOAD (HP)</u>	<u>INVERTER AMPS (ØB)</u>	<u>TEST MOTOR AMPS (ØB)</u>	<u>TEST MOTOR AMPS (ØA)</u>	<u>REMARKS</u>
0	0	9.7	9.7	0	Starting
0	0.5	13.4	9.0	2.4*	Starting
200	0	10.5	9.7	.5	Starting
200	0.5	14.3	9.1	2.3*	Starting
0	0	3.2	3.2	0	Running
0	0.5	6.25	3.1	0	Running
200	0	4.9	3.8	1.1	Running
200	0.5	7.8	3.4	.6	Running

Of particular interest here is the test motor phase "A" current. Values marked "*" are supplied to the test motor from the other motors running on the bus. This current assists the test motor in starting. When the test motor gets up to speed, it is acting as a generator, along with the other motors, in supplying current to the non-motor load.

3.4 COMPUTER RESULTS

Figures 16 through 20 are graphs, plotted from computer data, of system current in phase "B" versus non-motor load in volt-amperes for various motor loads. The fault is placed on phase "A" and the phase "B" system current is plotted. Phase "B" was chosen to plot since it is consistently higher in magnitude than phase "C" and therefore represents the worse case condition. Since the ordinate of these curves is in per unit current, a horizontal line at the 1.0 point represents the full load line for phase "B." The dotted line represents the current anticipated on phase "B" during a series fault if

the magnetic coupling between motor phases is neglected. It takes into account the additional current required to supply the mechanical load from two rather than three phases, plus the additional current due to the higher slip. Examination of the curves shows that a significant error could result if one does not consider the coupling when making a load analysis. For example, figure 18 shows that the system, under balanced conditions, can handle 0.5 horsepower motor load plus an additional 600 volt-amperes of non-motor loads per phase. If coupling is neglected (dotted curve) during a series fault, one would erroneously expect the system to handle the 0.5 horsepower motor plus 415 volt-amperes of other loads when in fact it could handle only 347 volt-amperes of other loads. Families of curves for other motor loads are shown in the other figures.

Figure 21 gives a family of curves for various motor loads showing the current generated by phase "A" of the motor during a series fault. The current is again plotted versus volt-amperes of non-motor loads and shows current increasing as load increases. This is what would be expected since increasing load represents decreasing impedance. This plot vividly illustrates the problem addressed by this analysis; that is, the non-motor loads connected to the bus represent an additional load to the remaining two phases because of the generating action of the motors. Figure 22 shows the generated current in phase "A" as a function of motor horsepower during a shunt fault. This could be considered the limiting case of the series fault since the shunt fault really represents a zero impedance




FIGURE 16 - SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 0.1 HP MOTOR LOAD




FIGURE 17 - SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 0.25 HP MOTOR LOAD




FIGURE 18 - SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 0.5 HP MOTOR LOAD




FIGURE 19 - SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 0.75 HP MOTOR LOAD




FIGURE 20 - SYSTEM CURRENT VS. NON-MOTOR LOAD FOR 1.0 HP MOTOR LOAD




FIGURE 21 - GENERATED MOTOR CURRENTS DURING SERIES FAULT




FIGURE 22 - GENERATED MOTOR CURRENTS DURING SHUNT FAULT




FIGURE 23 - GENERATED VOLTAGE ON PHASE A DURING SERIES FAULT

load. Another parameter of interest is the voltage on bus "A" during a series fault. This represents the voltage, generated by the connected motors, impressed on the non-motor loads connected to bus "A" and could be a problem if these loads are sensitive to low voltage. A plot showing the magnitude of this voltage as a function of volt-amperes connected is shown in figure 23.

4.0 CONCLUSIONS AND RECOMMENDATIONS

4.1 CONCLUSIONS

Whereas 4-wire a.c. systems offer the advantage that 3-phase induction motors will start on two phases, their performance during fault conditions must be taken into account. In order to predict this performance, one must take into account the magnetic coupling between phases of the motors. This coupling can result in overloads on the system as well as undesirable voltages on the faulted phase. A method has been presented to estimate the magnitude of these voltages and currents quickly and easily for series and shunt faults. For example, it has been shown that the non-motor-load capacity of the Space Shuttle Orbiter system is approximately 16% lower than would be anticipated if coupling were not considered. It has also been shown that there exists a practical upper limit on the size of motor loads that will tolerate a shunt fault. For example, on the Orbiter this upper limit is less than 0.5 horsepower.

4.2 RECOMMENDATIONS

The program as developed does not permit reactive non-motor loads nor does it permit impedance-to-neutral type shunt faults. These features should be incorporated in later versions of the program. The addition of distribution system (source) impedance would be a useful feature also. It was not included in this version since the distribution impedance for most spacecraft is very low (3% or less voltage drop at full load).

REFERENCES

1. Fortescue, C. L., "Method of Symmetrical Coordinates Applied to the Solution of Polyphase Networks," Trans. AIEE 37: 1027-1140, 1918.
2. Alger, P. L., Induction Machines, Gordon and Breach Science Publishers, New York, 1969.
3. Clark, Edith, Circuit Analysis of AC Power Systems, General Electric Co., Schenectady, New York, 1950.
4. Westinghouse Electric Corporation, Electrical Transmission and Distribution Reference Book, 4th Edition, East Pittsburgh, Pennsylvania, 1964.
5. Lawrence, R. R., and Richards, H. E., Principles of Alternating-Current Machinery, McGraw-Hill Co., New York, 1953.
6. Lyndon B. Johnson Space Center, Shuttle Operational Data Book (JSC 08934, Volume 1, Revision A), Houston, Texas, October 1976.

APPENDIX A

FORTRAN LISTING - "SOPSFS"

ORIGINAL PAGE IS
OF POOR QUALITY

*** THIS PROGRAM IS WRITTEN IN FORTRAN AND SIMULATES SERIES AND SHUNT FAULTS ON THE SHUNT OR OTHER AC POWER SYSTEM. THE SERIES FAULT IS DEFINED AS A TOTAL OF ONE OF THE AC SYSTEM. AN EXAMPLE OF THIS IS THE LOSS OF ONE OF THE THREE SINGLE PHASE INVERTERS. THE SHUNT FAULT IS DEFINED AS A PHASE TO NEUTRAL SHORT CIRCUIT AFTER THE CIRCUIT BREAKER OR FUSE HAS DISCONNECTED THE SOURCE FROM THE FAULT.

** THE SIMULATED SYSTEM INCLUDES TWO TYPES OF LOADS, MOTOR AND NON-MOTOR LOADS. THE MOTOR LOADS ARE REPRESENTED BY A COMPOSITE EQUIVALENT CIRCUIT. THE EQUIVALENT CIRCUIT PARAMETERS ARE CALCULATED BY THE COMPUTER BASED ON TOTAL CONNECTED HORSEPOWER WHICH IS INPUT BY THE OPERATOR. THE NON-MOTOR LOADS ARE REPRESENTED BY A 3-PHASE, WYE CONNECTED RESISTIVE LOAD BANK. THE SIZE OF THE LOAD IN VOLT-AMPERES IS INPUT BY THE OPERATOR. THE ANALYTICAL METHOD USED IS COMMONLY REFERRED TO AS THE METHOD OF SYMMETRICAL COMPONENTS. BRIEFLY THIS METHOD TRANSFORMS THE PHASE QUANTITIES FROM THE "ABC" REFERENCE FRAME INTO A "ZPN" REFERENCE FRAME (ZERO, POSITIVE, AND NEGATIVE SEQUENCE). CALCULATIONS ARE MADE WHILE IN THE "ZPN" REFERENCE FRAME AND THEN TRANSFORMED BACK INTO THE "ABC" REF. FRAME.

** DEFINITIONS
R1, R2, X1, X2, AND XM - TRADITIONAL INDUCTION MOTOR EQUIVALENT CIRCUIT PARAMETERS EXPRESSED IN PER UNIT VALUES PER PHASE.
ZZ = RZ+JXZ - ZERO SEQUENCE IMPEDANCE IN PU PER PHASE.
BASE VOLT-AMPERES=750 VA (SINGLE PHASE INVERTER RATING)
BASE VOLTAGE = 120 VOLTS (PHASE TO NEUTRAL)
BASE CURRENT = 6.25 AMPS; BASE IMPEDANCE = 19.2 OHMS
CHP - SUM TOTAL OF ALL MOTORS CONNECTED TO BUS (EXPRESSED IN HP)
CHP IS ONE OF THE REQUIRED INPUTS.
VAC - SUM TOTAL OF ALL NON-MOTOR LOADS CONNECTED TO BUS (EXPRESSED IN VOLT-AMPS PER PHASE). VAC IS ALSO A REQUIRED INPUT.
S - MOTOR SLIP. THIS IS ALSO A REQUIRED INPUT.

A - COMPLEX OPERATOR = $\cos(120^\circ) + j\sin(120^\circ)$
AA - COMPLEX OPERATOR = $\cos(240^\circ) + j\sin(240^\circ)$
Z1 - POSITIVE AND NEGATIVE SEQUENCE
Z2 - POSITIVE SEQUENCE IMPEDANCE OF MOTOR WHICH IS A FUNCTION OF S.

Z2N - NEGATIVE SEQUENCE IMPEDANCE OF MOTOR WHICH IS A FUNCTION OF S.

ZPERP+JXPR; ZN=RN+JXN - POSITIVE AND NEGATIVE SEQUENCE IMPEDANCES OF MOTOR. BOTH ARE FUNCTIONS OF S.

ZZ=ZZ+JXZ - ZERO SEQUENCE IMPEDANCE OF MOTOR.

ZLER+JG - IMPEDANCE OF NON-MOTOR LOADS.

CIPL, CINL, CI7L - POSITIVE, NEGATIVE, AND ZERO SEQUENCE CURRENTS IN NON-MOTOR LOAD.

CIPM, CINM, CI7M - P, N, Z CURRENTS IN MOTOR.

CIP, CIN, CI7 - P, N, Z CURRENTS FROM SOURCE.

ZPS, ZNS, Z7S - TOTAL SYSTEM IMPEDANCES IN P, N, Z REF. FRAME.

EAP - PHASE A POSITIVE SEQUENCE VOLTAGE

VP, VM, VZ - P, N, Z FAULT VOLTAGES FOR SERIES FAULT.

EAP, EBP, ECP - ABC VOLTAGES ACROSS SERIES FAULT.

CIAP, CIBP, CICP - ABC CURRENTS FROM SOURCE.

CIAM, CIBM, CICM - ABC CURRENTS INTO MOTOR.

CIAP, CIBL, CICL - ABC CURRENTS INTO NON-MOTOR LOADS.

VA, VB, VC - ABC APPLIED VOLTAGES (PHASE TO NEUTRAL).

VAN, VBN, VCN - ABC PHASE VOLTAGES ACROSS MOTOR AND LOAD TERMINALS.

NS - COUNTER OF NUMBER OF SLIP POINTS. REQUIRED INPUT.

NCHP - COUNTER OF NUMBER OF HP VALVES. REQUIRED INPUT.

NVAC - COUNTER OF NUMBER OF LOAD VALVES. REQUIRED INPUT.

0001
0002
0003
0004
0005
0006
0007
0008
0009
0010
0011
0012
0013
0014
0015
0016
0017
0018
0019
0020
0026
0027
0028
0029
0030
0031
0032
0033
0034
0035
0036
0037
0038
0039
0040
0041
0042
0043
0044
0045
0046
0047
0048
0049
0051
0052
0053
0054
0055
0056
0057
0058
0059
0060
0061
0062
0063
0064
0065
0066

0067

```

22PP, 22NP - PARALLEL COMBINATION OF RIGOR IMPEDANCES AND MUTUAL-
INTEGER LP, 111, CDR, 110
COMPLEX A, AA, ZP, ZL, Z2, ZN, ZM, CIP1, C1N1, C1Z1, C1PH, C1NM, C1ZN, CIP,
C1N, C1Z, EAP, VP, VM, VZ, EAAP, EBHP, ECCP, CIA, C1P, C1A, C1NM, C1CM,
C1AL, C1NL, C1CL, VA, VB, VC, VAN, VCM, 22PP, 22NP, 71, 72P, 72N, ZPS, ZNS,
22S, VPM, ZA, ZB, ZC
DIMENSION S(10), CHP(10), VAC(10)
LP=6
CDR=5
READ INPUT DATA
READ(CDR, 10) NS, NCHP, NVAC
READ(CDR, 20) (S(I), I=1, NS)
READ(CDR, 20) (CHP(I), I=1, NCHP)
READ(CDR, 30) (VAC(I), I=1, NVAC)
FORMAT(315)
FORMAT(10F5.2)
FORMAT(10F7.2)
FORMAT(1H1, 5X, 'FAULT SIMULATION OF ORRITEN POWER SYSTEM')
FORMAT(1H0, 5X, 'SLIP PIS.=', 12, 5X, 'CHP PIS.=', 12, 5X, 'VAC PIS.=', 12
+)
WRITE(LP, 40)
WRITE(LP, 50) NS, NCHP, NVAC
FORMAT(1H0, 5X, 'VALUES OF SLIP, CONNECTED HP, AND CONNECTED LOAD A
+S FOLLOWS:')
WRITE(LP, 60)
FORMAT(1H0, 5X, 'VALUES OF SLIP (S) ARE:')
WRITE(LP, 70)
FORMAT(1H, 5X, 10F6.2)
WRITE(LP, 80) (S(I), I=1, NS)
FORMAT(1H0, 5X, 'VALUES OF CONNECTED HORSEPOWER ARE:')
WRITE(LP, 90)
FORMAT(1H, 5X, 10F6.2)
WRITE(LP, 100) (CHP(I), I=1, NCHP)
FORMAT(1H0, 5X, 'VALUES OF CONNECTED LOAD (VAC) ARE:')
WRITE(LP, 110)
FORMAT(1H, 5X, 10F6.2)
WRITE(LP, 120) (VAC(I), I=1, NVAC)
WE WILL COMPUTE CURRENTS AND VOLTAGES FOR BALANCED CONDITIONS
USING THE SAME TRANSFORMATION EQUATIONS AS WILL BE USED FOR
FAULT CONDITIONS. THIS IS BEING DONE PRIMARILY AS A CHECK ON
THE ARITHMETIC.
COMPUTATIONS FOR BALANCED CONDITIONS. TO BE MADE WITHIN 3 DO LOOPS.
WRITE(LP, 125)
FORMAT(1H0, 5X, 'PARAMETERS OF INTEREST FOR THE BALANCED CONDIT
+100 ARE AS FOLLOWS:')
WRITE(LP, 140)
WRITE(LP, 150)
WRITE(LP, 160)
WRITE(LP, 170)
FORMAT(1H, 1X, 'SE', F4.2, 51X, 'BALANCED')
ALL PARAMETERS ARE CONVERTED TO PER UNIT VALUES AND ALL RESULTS
ARE PRINTED AS PER UNIT VALUES.
BEGIN CALCULATIONS
PI=3.14159
A=CMPLX(COS(2.*PI/3.), SIN(2.*PI/3.))
AA=CMPLX(COS(4.*PI/3.), SIN(4.*PI/3.))
VB=CMPLX(1., 0.)
VC=CMPLX(-.5, -.866)
EAP=VA

```

0350
0355
0360

ORIGINAL PAGE IS
OF POOR QUALITY

```

DO 400 K=1,NVAC
DO 400 J=1,NCHP
DO 400 I=1,N5
WRITE(LP,406) S(I)
WRITE(LP,416) CHP(J)
WRITE(LP,426) VAC(K)
R1=.229*(.75/CHP(J))
X1=.135*(.75/CHP(J))
X2=X1
R2=.156*((.75/CHP(J))/S(I))
XM=.172*(.75/CHP(J))
KZ=.247*(.75/CHP(J))
XZ=.137*(.75/CHP(J))
R=750./VAC(K)
ZL=CMPLX(R,V.)
Z1=CMPLX(K1,X1)
R2P=R2
Z2P=CMPLX(R2P,X2)
R2N=.156*(.75/CHP(J))/(2-S(I))
Z2N=CMPLX(R2N,X2)
Z2=CMPLX(R2,X2)
ZP=CMPLX(U.,XM)
WE WILL NOW COMPUTE "ZPN" VOLTAGES
VZ=(1./SQRT(3.))* (VA+VB+VC)
VP=(1./SQRT(3.))* (VA+VB+AA*VC)
VN=(1./SQRT(3.))* (VA+AA*VB+AA*VC)
BEGIN REDUCTION OF MOTOR EQUIVALENT CIRCUIT.
Z2PP=ZM*Z2P/(ZM+Z2P)
Z2NP=ZM*Z2N/(ZM+Z2N)
ZP=Z1+Z2PP
ZN=Z1+Z2NP
CIZ=VZ/ZZ
CIP=VP/ZP
CIN=VN/ZN
WE WILL NOW COMPUTE ABC MOTOR CURRENTS.
CIAM=(1./SQRT(3.))* (CIZ+CIP+CIN)
CIMM=(1./SQRT(3.))* (CIZ+AA*CIP+AA*CIN)
CICM=(1./SQRT(3.))* (CIZ+AA*CIP+AA*CIN)
WE WILL NOW COMPUTE CURRENTS (ABC) IN RESISTIVE LOAD.
CIA=VA/ZL
CIAE=VB/ZL
CICLE=VC/ZL
WE WILL NOW COMPUTE PHASE VOLTAGE ON MOTOR TERMINALS.
VAM=(1./SQRT(3.))* (VZ+VP+VN)
VBM=(1./SQRT(3.))* (VZ+AA*VP+AA*VN)
VCM=(1./SQRT(3.))* (VZ+AA*VP+AA*VN)
AND FINALLY WE WILL COMPUTE SYSTEM CURRENTS.
CIA=CIA+CIAM
CIB=CIB+CIIM
CIC=CIC+CIAM+CIIM
THIS COMPLETES
BALANCED
OF INTEREST.
WRITE(LP,430) CIA,CIAM,CIAL,VAM
WRITE(LP,440) CIB,CIBM,CIBL,VBM
WRITE(LP,450) CIC,CICM,CICL,VCM
WE WILL NOW CLOSE THE DO LOOP.
CONTINUE
FORHAI(1HU,5X,'PARAMETERS OF INTEREST FOR THE SERIES FAULT CONDIT
+ION ARE AS FOLLOWS:'))

```

COMPUTATION OF VOLTAGES AND CURRENTS FOR THE
CONDITION. WE WILL NOW PRINT CURRENTS AND VOLTAGES

400
130

```

135  FORMAT(IH0,5X,'PARAMETERS OF INTEREST FOR THE SHORT FAULT CONDIT
+ION ARE AS FOLLOWS:',//)
140  WRITE(LP,150)
150  FORMAT(IH0,10X,'COMPLEX',7X,'COMPLEX',7X,'COMPLEX',7X,'COMPLEX')
160  FORMAT(IH,10X,'SYSTEM',9X,'MOTOR',9X,'LOAD',8X,'MOTOR TERM.')
170  FORMAT(IH,10X,'CURRENTS',6X,'CURRENTS',6X,'CURRENTS',6X,'VOL
+TAGE')
180  FORMAT(IH,12X,'(PU)',10X,'(PU)',10X,'(PU)',10X,'(PU)')
190  WRITE(LP,140)
200  WRITE(LP,150)
210  WRITE(LP,160)
220  WRITE(LP,170)
230  COMPUTATIONS FOR SERIES FAULT. (TO BE MADE WITHIN 3 DU LOOPS)
240  THE VALUE OF SLIP IS NOW ADJUSTED TO COMPENSATE FOR THE SLOWDOWN
+CAUSED BY THE SERIES FAULT.
250  DO 499 I=1,NS
260  S(I)=S(J)+.01
270  CONTINUE
280  DO 500 K=1,NVAC
290  DO 500 J=1,NCHP
300  DO 500 I=1,NS
310  X1=.229*(.75/CHP(J))
320  X1=.135*(.75/CHP(J))
330  X2=X1
340  X2=.156*(.75/CHP(J))/S(I)
350  X3=.172*(.75/CHP(J))
360  X4=.247*(.75/CHP(J))
370  X5=.137*(.75/CHP(J))
380  X6=.750/VAC(K)
390  ZL=CHPLX(R,0.)
400  Z1=CHPLX(R1,X1)
410  Z2=CHPLX(R2,X2)
420  Z3=CHPLX(R3,X3)
430  Z4=CHPLX(R4,X4)
440  Z5=CHPLX(R5,X5)
450  Z6=CHPLX(R6,X6)
460  Z7=CHPLX(R7,X7)
470  Z8=CHPLX(R8,X8)
480  Z9=CHPLX(R9,X9)
490  Z10=CHPLX(R10,X10)
500  Z11=CHPLX(R11,X11)
510  Z12=CHPLX(R12,X12)
520  Z13=CHPLX(R13,X13)
530  Z14=CHPLX(R14,X14)
540  Z15=CHPLX(R15,X15)
550  Z16=CHPLX(R16,X16)
560  Z17=CHPLX(R17,X17)
570  Z18=CHPLX(R18,X18)
580  Z19=CHPLX(R19,X19)
590  Z20=CHPLX(R20,X20)
600  Z21=CHPLX(R21,X21)
610  Z22=CHPLX(R22,X22)
620  Z23=CHPLX(R23,X23)
630  Z24=CHPLX(R24,X24)
640  Z25=CHPLX(R25,X25)
650  Z26=CHPLX(R26,X26)
660  Z27=CHPLX(R27,X27)
670  Z28=CHPLX(R28,X28)
680  Z29=CHPLX(R29,X29)
690  Z30=CHPLX(R30,X30)
700  Z31=CHPLX(R31,X31)
710  Z32=CHPLX(R32,X32)
720  Z33=CHPLX(R33,X33)
730  Z34=CHPLX(R34,X34)
740  Z35=CHPLX(R35,X35)
750  Z36=CHPLX(R36,X36)
760  Z37=CHPLX(R37,X37)
770  Z38=CHPLX(R38,X38)
780  Z39=CHPLX(R39,X39)
790  Z40=CHPLX(R40,X40)
800  Z41=CHPLX(R41,X41)
810  Z42=CHPLX(R42,X42)
820  Z43=CHPLX(R43,X43)
830  Z44=CHPLX(R44,X44)
840  Z45=CHPLX(R45,X45)
850  Z46=CHPLX(R46,X46)
860  Z47=CHPLX(R47,X47)
870  Z48=CHPLX(R48,X48)
880  Z49=CHPLX(R49,X49)
890  Z50=CHPLX(R50,X50)
900  Z51=CHPLX(R51,X51)
910  Z52=CHPLX(R52,X52)
920  Z53=CHPLX(R53,X53)
930  Z54=CHPLX(R54,X54)
940  Z55=CHPLX(R55,X55)
950  Z56=CHPLX(R56,X56)
960  Z57=CHPLX(R57,X57)
970  Z58=CHPLX(R58,X58)
980  Z59=CHPLX(R59,X59)
990  Z60=CHPLX(R60,X60)
1000  Z61=CHPLX(R61,X61)
1010  Z62=CHPLX(R62,X62)
1020  Z63=CHPLX(R63,X63)
1030  Z64=CHPLX(R64,X64)
1040  Z65=CHPLX(R65,X65)
1050  Z66=CHPLX(R66,X66)
1060  Z67=CHPLX(R67,X67)
1070  Z68=CHPLX(R68,X68)
1080  Z69=CHPLX(R69,X69)
1090  Z70=CHPLX(R70,X70)
1100  Z71=CHPLX(R71,X71)
1110  Z72=CHPLX(R72,X72)
1120  Z73=CHPLX(R73,X73)
1130  Z74=CHPLX(R74,X74)
1140  Z75=CHPLX(R75,X75)
1150  Z76=CHPLX(R76,X76)
1160  Z77=CHPLX(R77,X77)
1170  Z78=CHPLX(R78,X78)
1180  Z79=CHPLX(R79,X79)
1190  Z80=CHPLX(R80,X80)
1200  Z81=CHPLX(R81,X81)
1210  Z82=CHPLX(R82,X82)
1220  Z83=CHPLX(R83,X83)
1230  Z84=CHPLX(R84,X84)
1240  Z85=CHPLX(R85,X85)
1250  Z86=CHPLX(R86,X86)
1260  Z87=CHPLX(R87,X87)
1270  Z88=CHPLX(R88,X88)
1280  Z89=CHPLX(R89,X89)
1290  Z90=CHPLX(R90,X90)
1300  Z91=CHPLX(R91,X91)
1310  Z92=CHPLX(R92,X92)
1320  Z93=CHPLX(R93,X93)
1330  Z94=CHPLX(R94,X94)
1340  Z95=CHPLX(R95,X95)
1350  Z96=CHPLX(R96,X96)
1360  Z97=CHPLX(R97,X97)
1370  Z98=CHPLX(R98,X98)
1380  Z99=CHPLX(R99,X99)
1390  Z100=CHPLX(R100,X100)
1400  Z101=CHPLX(R101,X101)
1410  Z102=CHPLX(R102,X102)
1420  Z103=CHPLX(R103,X103)
1430  Z104=CHPLX(R104,X104)
1440  Z105=CHPLX(R105,X105)
1450  Z106=CHPLX(R106,X106)
1460  Z107=CHPLX(R107,X107)
1470  Z108=CHPLX(R108,X108)
1480  Z109=CHPLX(R109,X109)
1490  Z110=CHPLX(R110,X110)
1500  Z111=CHPLX(R111,X111)
1510  Z112=CHPLX(R112,X112)
1520  Z113=CHPLX(R113,X113)
1530  Z114=CHPLX(R114,X114)
1540  Z115=CHPLX(R115,X115)
1550  Z116=CHPLX(R116,X116)
1560  Z117=CHPLX(R117,X117)
1570  Z118=CHPLX(R118,X118)
1580  Z119=CHPLX(R119,X119)
1590  Z120=CHPLX(R120,X120)
1600  Z121=CHPLX(R121,X121)
1610  Z122=CHPLX(R122,X122)
1620  Z123=CHPLX(R123,X123)
1630  Z124=CHPLX(R124,X124)
1640  Z125=CHPLX(R125,X125)
1650  Z126=CHPLX(R126,X126)
1660  Z127=CHPLX(R127,X127)
1670  Z128=CHPLX(R128,X128)
1680  Z129=CHPLX(R129,X129)
1690  Z130=CHPLX(R130,X130)
1700  Z131=CHPLX(R131,X131)
1710  Z132=CHPLX(R132,X132)
1720  Z133=CHPLX(R133,X133)
1730  Z134=CHPLX(R134,X134)
1740  Z135=CHPLX(R135,X135)
1750  Z136=CHPLX(R136,X136)
1760  Z137=CHPLX(R137,X137)
1770  Z138=CHPLX(R138,X138)
1780  Z139=CHPLX(R139,X139)
1790  Z140=CHPLX(R140,X140)
1800  Z141=CHPLX(R141,X141)
1810  Z142=CHPLX(R142,X142)
1820  Z143=CHPLX(R143,X143)
1830  Z144=CHPLX(R144,X144)
1840  Z145=CHPLX(R145,X145)
1850  Z146=CHPLX(R146,X146)
1860  Z147=CHPLX(R147,X147)
1870  Z148=CHPLX(R148,X148)
1880  Z149=CHPLX(R149,X149)
1890  Z150=CHPLX(R150,X150)
1900  Z151=CHPLX(R151,X151)
1910  Z152=CHPLX(R152,X152)
1920  Z153=CHPLX(R153,X153)
1930  Z154=CHPLX(R154,X154)
1940  Z155=CHPLX(R155,X155)
1950  Z156=CHPLX(R156,X156)
1960  Z157=CHPLX(R157,X157)
1970  Z158=CHPLX(R158,X158)
1980  Z159=CHPLX(R159,X159)
1990  Z160=CHPLX(R160,X160)
2000  Z161=CHPLX(R161,X161)
2010  Z162=CHPLX(R162,X162)
2020  Z163=CHPLX(R163,X163)
2030  Z164=CHPLX(R164,X164)
2040  Z165=CHPLX(R165,X165)
2050  Z166=CHPLX(R166,X166)
2060  Z167=CHPLX(R167,X167)
2070  Z168=CHPLX(R168,X168)
2080  Z169=CHPLX(R169,X169)
2090  Z170=CHPLX(R170,X170)
2100  Z171=CHPLX(R171,X171)
2
```

```

FAAPE VP+VZ+VN
EBRPE VZ+AA*VP+AA*VN
ECCPE VZ+AA*VP+AA*VN
WE WILL NOW COMPUTE SYSTEM CURRENTS IN ABC REFERENCE FRAME.
CIA=CIZ+CIP+CIN
CIB=CIZ+AA*CIP+AA*CIN
CIC=CIZ+AA*CIP+AA*CIN
WE WILL NOW COMPUTE MOTOR CURRENTS IN THE ZPN REFERENCE FRAME.
CIZM=(CIZ*ZL)/(ZZ+ZL)
CIPM=(CIP*ZL)/(ZP+ZL)
CINM=(CIN*ZL)/(ZN+ZL)
WE WILL NOW COMPUTE MOTOR CURRENTS IN THE ABC REFERENCE FRAME.
CIAM=CIZM+CIPM+CINM
CIBM=CIZM+AA*CIPM+AA*CINM
CICM=CIZM+AA*CIPM+AA*CINM
WE WILL NOW COMPUTE CURRENTS INTO RESISTIVE LOAD. (ABC REF. FRAME)
CIAL=CIA-CIAM
CICL=CIC-CICM
WE WILL NOW COMPUTE PHASE VOLTAGE ON MOTOR AND LOAD TERMINALS.
VAME=VA-EAAP
VBM=VB-EBBP
VCM=VC-ECCP
THIS SERIES COMPLETES COMPUTATION OF VOLTAGES AND CURRENTS FOR THE
OF INTEREST.
WRITE(LP,404) S(I)
FORMAT(IH,1X,'S=',F4.2,51X,'SERIES')
FORMAT(IH,1X,'S=',F4.2,51X,'SHUNT')
FORMAT(IH,1X,'CHP=',F4.2)
WRITE(LP,410) CHP(J)
FORMAT(IH,1X,'VAC=',F4.0)
FORMAT(IH,2X,'PH A',2X,2F6.3,2X,2F6.3,2X,2F6.3,3X,2F6.3)
WRITE(LP,430) CIA,CIAM,CIAL,VAM
FORMAT(IH,2X,'PH B',2X,2F6.3,2X,2F6.3,2X,2F6.3,3X,2F6.3)
WRITE(LP,440) CIB,CIBM,CIBL,VBM
FORMAT(IH,2X,'PH C',2X,2F6.3,2X,2F6.3,2X,2F6.3,3X,2F6.3)
WRITE(LP,450) CIC,CICM,CICL,VCM
WE WILL NOW CLOSE THE DO LOOP.
CONTINUE
WE WILL NOW BEGIN SETTING UP CONDITIONS FOR THE SHUNT FAULT. HERE
AGAIN WE WILL PLACE FAULT ON PHASE A. THE SOLUTION METHOD FOR
THE SHUNT FAULT WILL BE DIFFERENT FROM THE SERIES FAULT SINCE
THE TERMINAL VOLTAGE ON THE FAULTED PHASE OF THE MOTOR/LOAD
WILL BE ZERO. ALSO NONE OF THE CURRENT INDUCED IN THE PHASE A
MOTOR WINDING WILL FLOW IN THE RESISTIVE LOAD. THIS SIMPLIFIES
THE PROBLEM BY PERMITTING SEPARATE COMPUTATION OF MOTOR AND
LOAD CURRENTS AND THEN SUPERIMPOSING THESE TO OBTAIN SYSTEM
CURRENTS.
SET UP INPUT VOLTAGES FOR THE SHUNT FAULT.
WRITE(LP,135)
WRITE(LP,140)
WRITE(LP,150)
WRITE(LP,160)
WRITE(LP,170)
VA=CMPLX(0.,0.)
VB=CMPLX(0.,0.)
VC=CMPLX(-.5, -.866)

```

0630

0650

0670

0690

0710

0730

0735

0740

0805

0815

0820

0825

0830

0835

0840

0845

0850

0855

0860

```

**          0880
WE WILL NOW COMPUTE "ZPN" VOLTAGES
VZ=(1./SQRT(3.))*((VA+VB+VC)
VP=(1./SQRT(3.))*((VA+AA*VB+AA*VC)
VN=(1./SQRT(3.))*((VA+AA*VB+AA*VC)
**          0900
WE WILL NOW COMPUTE ZPN MOTOR CURRENTS.
THE VALUE OF SLIP IS NOW ADJUSTED TO COMPENSATE FOR THE SLOWDOWN
CAUSED BY THE SHUNT FAULT.
DO 799 I=1,NS
S(I)=S(I)+.1
CONTINUE
DO 800 K=1,NVAC
DO 800 J=1,NCHP
DO 800 I=1,NS
R1=-.229*(.75/CHP(J))
X1=-.135*(.75/CHP(J))
X2=X1
R2=-.156*(.75/CHP(J))/S(I)
XM=-.72*(.75/CHP(J))
RZ=-.247*(.75/CHP(J))
XZ=-.137*(.75/CHP(J))
R=750./VAC(K)
ZL=CMPLX(R,0.)
Z1=CMPLX(X1,X1)
R2P=R2
Z2P=CMPLX(X2,X2)
R2M=-.156*(.75/CHP(J))/(2-S(I))
Z2M=CMPLX(X2,X2)
Z2=CMPLX(XZ,XZ)
ZM=CMPLX(XZ,XZ)
BEGIN REDUCTION OF MOTOR EQUIVALENT CIRCUIT.
Z2PP=Z2+Z2P/(ZM+Z2P)
Z2MP=ZM+Z2N/(ZM+Z2N)
ZP=Z1+Z2PP
ZM=Z1+Z2MP
CIZ=VZ/ZZ
CIP=VP/ZP
CIN=VN/ZN
VCM=(1./SQRT(3.))*((VZ+AA*VP+AA*VN)
VBM=(1./SQRT(3.))*((VZ+AA*VP+AA*VN)
WE WILL NOW COMPUTE ABC MOTOR CURRENTS.
CIAM=(1./SQRT(3.))*((CIZ+CIP+CIN)
CIBM=(1./SQRT(3.))*((CIZ+AA*CIP+AA*CIN)
CICM=(1./SQRT(3.))*((CIZ+AA*CIP+AA*CIN)
WE WILL NOW COMPUTE CURRENTS (ABC) IN RESISTIVE LOAD.
CIAL=VA/ZL
CIRL=VP/ZL
CICL=VC/ZL
AND FINALLY WE WILL COMPUTE SYSTEM CURRENTS.
CIA=0.
CIB=CIBM+CIBL
CIC=CICM+CICL
THIS COMPUTES COMBINATION OF VOLTAGES AND CURRENTS FOR THE
SS SHUNT FAULT CONDITION. WE WILL NOW PRINT CURRENTS AND VOLTAGES
OF INTEREST.
WRITE(LP,405) S(I)
WRITE(LP,410) CHP(J)
WRITE(LP,420) VAC(K)
WRITE(LP,430) CIA,CIAM,CIAL,VAM
WRITE(LP,440) CIB,CIBM,CIBL,VBM
WRITE(LP,450) CIC,CICM,CICL,VCM

```

799

1115

1135

1155

WE WILL NOT CLOSE THE DO LOOP.
CONTINUE
END

**
800

APPENDIX B

FORTRAN LISTING - "SOTPMS"

02/08/80 09:09:52

PAGE 1

S E L E X T E N D E D F O R T R A N I V (R T V - 0 / 7 8 S E P 0 8)

MAIN

```

C***      THIS PROGRAM IS WRITTEN IN FORTRAN AND SIMULATES PERFORMANCE
C          CHARACTERISTICS OF THE ORBITER AC POWER SYSTEM DURING TWO PHASE
C          STARTING OF INDUCTION OF THE MOTORS.
C***      THE ORBITER AC SYSTEM IS SIMULATED AND INCLUDES MOTOR AND NON-
C          MOTOR TYPE LOADS. THE NON MOTOR LOADS ARE BALANCED, UNITY POWER
C          FACTOR TYPE LOADS. THE MOTOR LOADS ARE REPRESENTED BY A COMPOSITE
C          EQUIVALENT CIRCUIT. THE EQUIVALENT CIRCUIT PARAMETERS ARE
C          CALCULATED BY THE COMPUTER BASED ON TOTAL CONNECTED HORSEPOWER.
C***      THE ANALYTICAL METHOD USED IS COMMONLY REFERRED TO AS THE "METHOD
C          OF SYMMETRICAL COMPONENTS." BRIEFLY THIS METHOD TRANSFORMS THE
C          PHASE QUANTITIES FROM THE "ABC" REFERENCE FRAME INTO A "ZPN"
C          REFERENCE FRAME (ZERO, POSITIVE, AND NEGATIVE SEQUENCE).
C          CALCULATIONS ARE MADE WHILE IN THE "ZPN" REFERENCE FRAME AND
C          THEN TRANSFORMED BACK INTO THE "ABC" REF. FRAME.
C***      DEFINITIONS*****
C          R1,R2,X1,X2,YM - COMPOSITE EQUIVALENT CIRCUIT PARAMETERS OF THE
C          MOTORS OPERATING PRIOR TO STARTING THE TEST MOTOR IN PU PER PH.
C          ZZ=KZ+JXZ - COMPOSITE ZERO SEQUENCE IMPEDANCE IN PU PER PHASE.
C          R1T,R2T,X1T,X2T,XMT,ZZT,RZT,XZT - TEST MOTOR PARAMETERS.
C          BASE VOLT-AMPERES=750-VA (SINGLE PHASE INVERTER RATING)
C          CHP - SUM TOTAL OF ALL MOTORS OPERATING PRIOR TO STARTING THE
C          TEST MOTOR. THIS IS A REQUIRED INPUT AND IS EXPRESSED IN HP
C          HPT - HORSEPOWER OF TEST MOTOR.
C          VAC - SUM TOTAL OF ALL NON-MOTOR LOADS CONNECTED TO THE BUS
C          (EXPRESSED IN VOLT-AMPERES PER PHASE). VAC IS ALSO AN INPUT.
C          ST - SLIP OF OPERATING MOTORS.
C          A - COMPLEX OPERATOR = COS(120)+JSIN(120)
C          AA - COMPLEX OPERATOR = COS(240)+JSIN(240)
C          Z1 - COMPLEX IMPEDANCE OF MOTOR STATOR WINDING = R1+JX1 (SAFE
C          FOR POSITIVE AND NEGATIVE SEQUENCE)
C          Z2P - POSITIVE SEQUENCE IMPEDANCE OF ROTOR WHICH IS A FUNCTION
C          OF SLIP.
C          Z2N - NEGATIVE SEQUENCE IMPEDANCE OF ROTOR WHICH IS A FUNCTION
C          OF SLIP.
C          ZP=RP+JXP; ZN=RN+JXN - POSITIVE AND NEGATIVE SEQUENCE IMPEDANCES
C          OF MOTOR. BOTH ARE FUNCTIONS OF SLIP.
C          ZZ=KZ+JXZ - ZERO SEQUENCE IMPEDANCE OF MOTOR. IMPEDANCE NOTATIONS
C          NOTE: THE SUBSCRIPT #1 IS ADDED TO THE ABOVE IMPEDANCE NOTATIONS
C          TO INDICATE TEST MOTOR PARAMETERS.
C          ZL=K+JX - IMPEDANCE OF NON-MOTOR LOADS.
C          C1PL,C1NL,C1ZL - POSITIVE, NEGATIVE, AND ZERO SEQUENCE CURRENTS
C          IN NON-MOTOR LOAD.
C          C1PH,C1NH,C1Z - PNZ CURRENTS IN MOTOR.
C          C1P,C1N,C1Z - PN7 CURRENTS FROM SOURCE.
C          ZPS,ZNS,ZZS - TOTAL SYSTEM IMPEDANCES IN PN7 REF. FRAME.
C          FAP - PHASE A POSITIVE SEQUENCE VOLTAGE.
C          VP,VN,VZ - PNZ FAULT VOLTAGES ACROSS SERIES FAULT.
C          FAAP,ERNP,FCOP - ARC VOLTAGES ACROSS SERIES FAULT.
C          NOTE: THE ADDITION OF THE SUBSCRIPT "F" INDICATES THAT THE
C          PARAMETER REPRESENTS THE EQUIVALENT VALUE FOR ALL MOTORS
C          INCLUDING THE TEST MOTOR.
C          OPERATION:
C***

```

ORIGINAL PAGE IS
OF POOR QUALITY

02/08/80

PAGE 7

SEL EXTENDED FORTRAN IV (REV - 0 / 7 8 S E P 0 8)

MAIN

```

55 IN RUNNING THE PROGRAM, VALUES FOR VAC, CHP, HPT, ST MUST BE INPUT
56 AS DATA. SEE FOLLOWING FORMAT STATEMENTS. ALSO THE TOTAL NUMBER
57 OF TEST POINTS FOR EACH PARAMETER MUST BE INPUTTED.
58
59 DEFINITIONS CONT:
60 CIA, CIB, CIC - ABC CURRENTS FROM SOURCE
61 CIAM, CIBM, CICM - ABC CURRENTS INTO OPERATING MOTORS.
62 CIAL, CIBL, CICL - ABC CURRENTS INTO NON-MOTOR LOADS.
63 VA, VR, VC - ABC APPLIED VOLTAGES (PHASE TO NEUTRAL).
64 VAM, VBM, VCM - ABC PHASE VOLTAGES ACROSS MOTOR AND LOAD TERMINALS
65 NST - COUNTER OF NUMBER OF SLIP POINTS (REQUIRED INPUT)
66 NCHP - COUNTER OF HORSEPOWER VALUES (REQUIRED INPUT)
67 NVAC - COUNTER OF NUMBER OF LOAD VALUES (REQUIRED INPUT)
68 *****
69 INTFGER LP, ITI, CDR, TIO
70 COMPLEX A, AA, ZP, ZL, ZN, ZM, CIPL, CINL, CI7L, CIPM, CINM, CI7M, CIP,
71 CIN, CIZ, EAP, VP, VM, VZ, EAAP, EBRP, FCCP, CIA, CIB, CIC, CIAM, CIBM, CIPM,
72 CIAL, CIBL, CICL, VA, VR, VC, VAM, VBM, VCM, Z2PP, Z1, Z2P, Z1, Z2P, ZPS, ZDS,
73 Z7S, ZA, ZB, ZC
74 COMPLEX Z1T, Z2PT, Z2NT, Z2T, ZMT, Z2PPT, Z2NPT, ZPT, ZNI, ZPF, ZHF, ZFE,
75 CIZME, CIPME, CINME, CIAME, CIBME, CICME, CIZMT, CIPMT, CINMT, CIAHT,
76 CIBMT, CIBCT
77 DIMENSION CHP(10), VAC(10), ST(10)
78 LP=6
79 CDR=5
80 READ INPUT DATA
81 READ(CDR, 10) NST, NCHP, NVAC
82 READ(CDR, 20) (ST(I), I=1, NST)
83 READ(CDR, 20) (CHP(I), I=1, NCHP)
84 READ(CDR, 30) (VAC(I), I=1, NVAC)
85 FORMAT(315)
86 FORMAT(10F5.2)
87 FORMAT(10F7.2)
88 FORMAT(F5.2)
89 READ(CDR, 32) HPT
90 FORMAT(1H, 5X, 'TWO PHASE STARTING OF ORRITER INDUCTION MOTORS'//)
91 WRITE(LP, 46)
92 FORMAT(1H0, 5X, 'SLIP PTS.=', I2, 5X, 'CHP PTS.=', I2, 5X, 'VAC PTS.=',
93 I2)
94 WRITE(LP, 50) NST, NCHP, NVAC
95 FORMAT(1H0, 5X, 'HP OF TEST MOTOR=', F5.2)
96 WRITE(LP, 52) HPT
97 FORMAT(1H0, 5X, 'VALUES OF SLIP (ST) ARE:'//)
98 WRITE(LP, 70)
99 FORMAT(1H, 5X, 10F6.2)
100 WRITE(LP, 80) (ST(I), I=1, NST)
101 FORMAT(1H0, 5X, 'VALUES OF CONNECTED HORSEPOWER ARE:'//)
102 WRITE(LP, 90)
103 WRITE(LP, 80) (CHP(I), I=1, NCHP)
104 FORMAT(1H0, 5X, 'VALUES OF CONNECTED LOAD ARE:'//)
105 WRITE(LP, 110)
106 FORMAT(1H, 5X, 10F6.2)
107 WRITE(LP, 82) (VAC(I), I=1, NVAC)
108 BEGIN CALCULATIONS
109 FORMAT(1H0, 5X, 'PARAMETERS OF INTEREST ARE AS FOLLOWS:'//)

```

SEL EXTENDED FORTRAN IV (REV - 0 / 7 8 S E P 0 8)

MAIN

```

109 WRITE(LP,130)
110 FORMAT(1H0,10X,'COMPLEX',7X,'COMPLEX',7X,'COMPLEX',7X,'COMPLEX',
111 +7X,'COMPLEX')
112 FORMAT(1H,10X,'SYSTEM',9X,'MOTOR',6X,'TEST MOTOR',6X,'MOTOR IFR
113 +M',4X,'LOAD')
114 FORMAT(1H,10X,'CURRENTS',6X,'CURRENTS',6X,'CURRENTS',6X,'VOLTAGE
115 +',7X,'CURRENTS')
116 FORMAT(1H,12X,'(PU)',10X,'(PU)',10X,'(PU)',10X,'(PU)',10X,'(PU)
117 +')
118 WRITE(LP,140)
119 WRITE(LP,150)
120 WRITE(LP,160)
121 WRITE(LP,170)
122 S=.06
123 PI=3.14159
124 A=CMPLX(COS(2.*PI/3.),SIN(2.*PI/3.))
125 AA=CMPLX(4.*PI/3.),SIN(4.*PI/3.))
126 VA=CMPLX(1.,0.)
127 VR=CMPLX(-.5,-.866)
128 VC=CMPLX(-.5,.866)
129 EAP=VA
130 DO 500 K=1,NVAC
131 DO 500 J=1,NCHP
132 DO 500 I=1,NST
133 RI=0.097*(.75/HPT)
134 XI=0.256*(.75/HPT)
135 X2I=XI
136 R2I=1.74*(.75/HPT)
137 XM=2.605*(.75/HPT)
138 R7I=1.65*(.75/HPT)
139 X7I=1.65*(.75/HPT)
140 Z1I=CMPLX(R1I,X1I)
141 R2PT=R2I/ST(I)
142 Z2PT=CMPLX(R2PT,X2I)
143 R2NT=1.74*(.75/HPT)/(2-ST(I))
144 Z2NT=CMPLX(R2NT,X2I)
145 Z7I=CMPLX(R7I,X7I)
146 ZMT=CMPLX(0,XMT)
147 BFGIN REDUCTION OF TEST MOTOR EO. CKT.
148 Z2PPT=ZMT+Z2PT/(ZMT+Z2PT)
149 Z2NPT=ZMT+Z2NT/(ZMT+Z2NT)
150 ZMT=Z1I+Z2PPT
151 ZNT=Z1I+Z2NPT
152 R1=0.097*(.75/CHP(J))
153 X1=0.256*(.75/CHP(J))
154 X2=X1
155 R2=1.74*(.75/CHP(J))
156 XM=2.605*(.75/CHP(J))
157 R7=1.65*(.75/CHP(J))
158 X7=1.65*(.75/CHP(J))
159 Z1=CMPLX(R1,X1)
160 R2P=R2/S
161 ZPP=CMPLX(R2P,X2)
162 RPN=1.74*(.75/CHP(J))/(2-S)

```

02/08/80

09:10:14

PAGE 4

SEL EXTENDED FORTRAN IV (REV - 0 / 7 8 S E P 0 8)

MAIN

```

163 Z2N=CMPLX(R2M,X2)
164 ZZ=CMPLX(RZ,XZ)
165 ZM=CMPLX(OM,XM)
166 R=750./VAC(K)
167 ZL=CMPLX(RL,0.)
168 BEGIN REDUCTION OF COMPOSITE MOTOR EQ. CKT.
169 Z2PP=ZM*Z2P/(ZM+Z2P)
170 Z2NP=ZM*Z2N/(ZM+Z2N)
171 ZP=Z1+Z2PP
172 ZN=Z1+Z2NP
173 BEGIN COMPUTATION OF THE PARALLEL COMBINATION OF TEST MOTOR AND
174 OTHER MOTORS. THE SUBSCRIPT "E" WILL BE USED TO INDICATE EQ. I.M.P.
175 ZPE=ZPT*ZP/(ZPT+ZP)
176 ZNE=ZNT*ZN/(ZNT+ZN)
177 ZFE=ZFI*ZF/(ZFI+ZF)
178 BEGIN COMPUTATION OF THE COMBINED SYSTEM IMPEDANCE.
179 ZPS=ZL*ZPE/(ZL+ZPE)
180 ZNS=ZL*ZNE/(ZL+ZNE)
181 ZFS=ZL*ZFE/(ZL+ZFE)
182 BEGIN COMPUTATION OF POSITIVE, NEGATIVE, AND ZERO SEQUENCE
183 CURRENTS (CIP, CIN, CIZ) FOR THE INTERCONNECTED SYSTEM.
184 CIP=(EAP*(ZNS+ZFS)/((ZPS*ZNS)+(ZPS*ZFS))+((ZPS*ZNS)+(ZNS*ZFS)))
185 CINE=-(EAP*ZFS)/((ZPS*ZNS)+(ZPS*ZFS))+((ZNS*ZFS)+(ZNS*ZFS))
186 CIZ=-(EAP*ZNS)/((ZPS*ZNS)+(ZPS*ZFS))+((ZNS*ZFS)+(ZNS*ZFS))
187 BEGIN COMPUTATION OF FAULT VOLTAGES IN THE ZPN REF. FRAME.
188 VP=VAP-(CIP*ZPS)
189 VNE=-(CIN*ZNS)
190 VZE=-(CIZ*ZFS)
191 BEGIN COMPUTATION OF THE VOLTAGE DROP ACROSS THE FAULT IN THE
192 ABC REF. FRAME USING THE TRANSFORMATION.
193 EAP=VP+V7+VN
194 EBP=VZ+AA*VP+AA*VN
195 ECCP=VZ+AA*VP+AA*VN
196 BEGIN COMPUTATION OF SYSTEM CURRENTS IN THE ABC REF. FRAME.
197 CIA=CIZ+CIH+CIN
198 CIB=CIZ+AA*CIP+AA*CIN
199 CIC=CIZ+AA*CIP+AA*CIN
200 BEGIN COMPUTATION OF TOTAL MOTOR CURRENTS IN THE ZPN REF. FRAME.
201 CIZME=CIZ*ZL/(ZZE+ZL)
202 CIPME=CIP*ZL/(ZPE+ZL)
203 CINME=CIN*ZL/(ZNE+ZL)
204 COMPUTE TOTAL MOTOR CURRENT IN THE ABC REF. FRAME.
205 CIAME=CIZME+CIHME+CINME
206 CIBME=CIZME+AA*CIHME+AA*CINME
207 CICME=CIZME+AA*CIHME+AA*CINME
208 COMPUTE CURRENT TO RESISTIVE LOAD (ABC).
209 CIAL=CIH-CIAME
210 CICH=CIH-CIBME
211 CICL=CIC-CICME
212 COMPUTE PHASE VOLTAGE ON MOTOR AND LOAD TERMINALS.
213 VAE=VA-FAAP
214 VBE=VB-FBRP
215 VCE=VC-ECCP
216 COMPUTE STARTING CURRENT OF TEST MOTOR.

```

ORIGINAL PAGE 15
OF 300 QUALITY

SEL EXTENDED FORTRAN IV (REV - 0 / 7 8 S E P 0 8)

MAIN

```

217 C1/MT=CIZME*ZZ/(ZZ+ZZT)
218 CIPMT=CIPME*ZP/(ZP+ZPT)
219 C1/MT=C1/MT*ZN/(ZN+ZNT)
220 C1/MT=C1/MT*ZN/(ZN+ZNT)
221 C1/MT=C1/MT*ZN/(ZN+ZNT)
222 C1/MT=C1/MT*ZN/(ZN+ZNT)
223 C1/MT=C1/MT*ZN/(ZN+ZNT)
224 C1/MT=C1/MT*ZN/(ZN+ZNT)
225 C1/MT=C1/MT*ZN/(ZN+ZNT)
226 C1/MT=C1/MT*ZN/(ZN+ZNT)
227 C1/MT=C1/MT*ZN/(ZN+ZNT)
228 C1/MT=C1/MT*ZN/(ZN+ZNT)
229 C1/MT=C1/MT*ZN/(ZN+ZNT)
230 C1/MT=C1/MT*ZN/(ZN+ZNT)
231 C1/MT=C1/MT*ZN/(ZN+ZNT)
232 C1/MT=C1/MT*ZN/(ZN+ZNT)
233 C1/MT=C1/MT*ZN/(ZN+ZNT)
234 C1/MT=C1/MT*ZN/(ZN+ZNT)
235 C1/MT=C1/MT*ZN/(ZN+ZNT)
236 C1/MT=C1/MT*ZN/(ZN+ZNT)
237 C1/MT=C1/MT*ZN/(ZN+ZNT)
238 C1/MT=C1/MT*ZN/(ZN+ZNT)
239 C1/MT=C1/MT*ZN/(ZN+ZNT)
240 C1/MT=C1/MT*ZN/(ZN+ZNT)
241 C1/MT=C1/MT*ZN/(ZN+ZNT)
242 C1/MT=C1/MT*ZN/(ZN+ZNT)
243 C1/MT=C1/MT*ZN/(ZN+ZNT)
244 C1/MT=C1/MT*ZN/(ZN+ZNT)
245 C1/MT=C1/MT*ZN/(ZN+ZNT)
246 C1/MT=C1/MT*ZN/(ZN+ZNT)

```

C*
C**
C
410
404
420
430
440
450
C* 500

THIS COMPLETES COMPUTATION OF VOLTAGES AND CURRENTS. PARAMETERS
OF INTEREST WILL NOW BE PRINTED.
FORMAT(1H,1X,1CHP=,F4.2)
WRITE(1H,1X,1ST=,F4.2)
WRITE(LP,404)ST(1)
FORMAT(1H,1X,1VAC=,F6.2)
WRITE(LP,420)VAC(K)
FORMAT(1H,2X,1PH A',2X,2F6.3,2X,2F6.3,2X,2F6.3,3X,2F6.3,3X,
+2F6.3)
WRITE(LP,430)CIA,CIAM,CIAMT,VAM,CIAL
FORMAT(1H,2X,1PH B',2X,2F6.3,2X,2F6.3,2X,2F6.3,3X,2F6.3,3X,
+2F6.3)
WRITE(LP,440)CIB,CIAM,CIBMT,VBM,CIBL
FORMAT(1H,2X,1PH C',2X,2F6.3,2X,2F6.3,2X,2F6.3,3X,2F6.3,3X,
+2F6.3)
WRITE(LP,450)CIC,CICF,CICMT,VCM,CICL
CLOSE UN LOOP
CONTINUE
END